





Mon 8/4/2014 12:52 PM

Brian Prunty <bprunty@summitswcd.org>

Re: Skimmer Approval

To  Tammy

Cc  jamie@swfeesaver.com

 You forwarded this message on 8/4/2014 4:26 PM.

Tammy,

I did review the 2 attached documents and they are the documents I was speaking about. Specifically, a surface skimmer is required to be used and the sediment basin shall dewater between 2-7 days (preferred 3 day drain time). As long as the proposed product meets those two items, it will be approved. When submitting your SWP3, please include our sediment basin data form (available on our website) along with your draw down calcs.

If you have any additional questions, please do not hesitate to contact me.

Thanks,
Brian

Brian Prunty CPSWQ, CPESC
Stormwater Specialist
Summit SWCD
330-929-2871 x14